

## Site (Structure) : BRINJE S

Country: SLOVENIA

Reporting Year: 2005

Full Name: Central Storage Facility for Radioactive Waste in Brinje (CISF)

Description:

Official Website:

License Holder(s): ARAO - Agency for Radwaste Management, Parmova 53, SI-1000 Ljubljana, Slovenia

Waste management facilities that are located at this site:

<b>Facility:</b>	<b>CISF</b>
<b>Description:</b>	Central Storage Facility for Radioactive Waste in Brinje. A storage for low and intermediate level waste from small producers (medicine, industry and research).

**Storage part of facility CISF**

The following shows storage status for waste classes and SRS.

Waste Class	Actual	Planned
LILW	Yes	Yes
HLW	No	No

List SRS?	Yes
List UMMT?	No

Capacity:	~500 m3.
-----------	----------

## Types of Storage Units

Storage Unit Name	Type Name	Year Opened	Closed?	Full?	Modular?	Contains SRS?
CISF-LILW	building	1986	No	No	No	Yes

Comment **# 12166: Storage Facility CISF**

The storage is a near-surface concrete building with the roof covered with a soil layer. The building is subdivided by concrete walls into nine storage sections and an entrance area. The ground plan of the facility is 10.6 m x 25.7 m with a height of 3.6 m. The useful capacity of the storage is about 500 m<sup>3</sup>, and the remaining small area is intended for workers, for loading and unloading the waste and for internal transport. The storage section at the back end of the building is deeper relative to the level of the other sections, and is intended for storage of more active spent sources. The facility is equipped with a ventilation system for reducing radon concentration and air contamination in the storage facility. The water and sewage collecting system is designed as a closed system to retain all liquids from the storage facility in the sump. Liquids are discharged after the measurements of the radioactive contamination which has to be below the limitation in the regulation. The electricity supply system is used for illumination of the storage facility, for heating of auxiliary rooms and for the powering of ventilation. The storage facility is also protected by an alarm system which is connected to a 24-hour security service.